

# Required Inspections per 2014 NEC

Medina County Building Department

Swimming Pool (330)-722-9220		
Inspector	Date	Inspection Name
		WALL/SHELL BONDING with at least 4 tails
		PERIMETER BONDING GRID
		PERIMETER BONDING, LOOP CONDUCTOR
		MOUNTING BASE BONDING
		ASSOC. EQUIPMENT BND pool grid to motor
		UNDERWATER BONDING PLATE
		URD LIGHT NICHE
		URD FROM MOTOR to pool cover
		URD FROM BUILDING to equipment/motor
		GND POTTING COMPOUND # of wet niche lights
		FINAL EQUIPMENT CONNECTIONS
		FINAL PANEL CONNECTIONS
		OTHER:
		OTHER:

## **\*\*NOTE\*\***

Not all of the above inspections are required for every pool installation. The electrical contractor is responsible for obtaining ALL inspections relative to this specific installation.

## **POOL HEATERS/GAS PIPING per 2013 RCO**

The pool contractor may obtain the pool heater permit.  
Gas piping shall be inspected under this permit.

*As the undersigned, I have read and understand all information contained herein. I agree to schedule all inspections with no less than 24-hour advance notice. The building will be occupied only for the necessary and essential construction of the structure, until such time I am granted a Certificate of Occupancy by the building official.*

Signature \_\_\_\_\_

Contractor/Owner