

PROJECT ADDRESS:

DECK BY:

CHECK LIST

● Exterior wood will be naturally durable or quality mark as pressure-preservative-treated in accordance with AWPA U1.

● **Fasteners** will be hot dipped zinc-coated galvanized steel, stainless steel, silicon bronze or copper.

● 36" minimum Guard will be provided along open-sides of deck walking surface located 30" or more above Grade below.

● 4" Sphere will not pass thru any guard openings.

36" Guard minimum

Deck Ledger
Flashing
Joist Hanger

Floor Joist Size – 2" x @ on center.

Height Above Grade

Span of Overhang

Joist Span

Beam Size – ply, 2" x

Post Size - x @ on center.

Post/Beam Connector with **Fasteners**

38" Depth Below Grade – minimum

Fasteners will be 1/2" diameter lag screws or bolts with washers: Deck Beam and Deck Ledger to Band-Rim Board will be staggered high and low @ 16" on center minimum (Section 502.2.2.1).

Footer Size